

Annexure

PRIMARY HEALTH CENTRE

AT : HOND, CHIKHLI, DIST : NAVSARI-396521

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. _____

Date: 06.07.2019

It is certified that an inspection team headed by Dr. Narmada N. Patel from Primary Health Centre, Hond, Chikhli inspected the Shree Swaminarayan International Gunatit Vidhyadham, situated Juna Valsad Road, Samroli, Chikhli, Dist : Navsari-396521 on 06.07.2019 and found that the school has safe drinking water facilities for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Govt.

The above valid for a period of Two Years

Dr. Narmada N. Patel
Primary Health Centre
Hond, Chikhli
Medical Officer,
P. H. C. Hond
Ta. Chikhli, Dist. Navsari.



To

Shree Swaminarayan International Gunatit Vidhyadham
Juna Valsad Road,
Samroli, Chikhli,
Dist : Navsari-396521



Jhanshi
Principal
Shree Swaminarayan International
Gunatit Vidyadham
Chikhli, Dist. Navsari



DISTRICT LABORATORY
GUJARAT WATER SUPPLY & SEWERAGE BOARD
NAVSARI
REPORT ON SHORT CHEMICAL EXAMINATION OF WATER

Name & Address:-

The Officer (Admn.)

Senders Ref.No:

Nil Dtd. 17/01/2019

Shri Swaminarayan International Gunatit Vidyadham

Date of Collection : 17/01/2019

Juna Valsad Road

Date of Arrival : 17/01/2019

At.-Samaroli

Lab.Ref.No. NCW : 5060

Tal-Chikhli

Collected by : Sender

Dist.-Navsari

SOURCE : Bore of School Campus					
Village :	Samaroli	Taluka:	Chikhli	District:	Navsari
Sr.No.	CHARACTERISTIC	IS-10500.(1991)-Edition 2:2 (2003-09)		Analytical Values	
		Desirable	Permissible		
1	Colour Hazen Unit	5	25	Colourless	
2	Odour	UO	UO	Odourless	
3	Turbidity NTU	5	10	Nil	
4	Dissolved Solids mg/l	500	2000	462	
5	pH	6.5 to 8.5	-	7.90	
6	Total Hardness (as CaCO ₃) mg/l	300	600	248	
7	Calcium (as Ca) mg/l	75	200	48	
8	Magnesium (as Mg) mg/l	30	100	31	
9	Chloride (as Cl) mg/l	250	1000	104	
10	Sulphate (as SO ₄) mg/l	200	400	27	
11	Nitrate (as NO ₃) mg/l	45	No Relaxation	1.75	
12	Fluoride (as F) mg/l	1.00	1.50	0.18	
13	Alkalinity (as CaCO ₃) mg/l	200	600	112	
14	--	--	--	--	
15	--	--	--	--	

OPINION FOR POTABILITY [As per IS:10500 (1991)-Edition 2:2 (2003-09)] :THE RESULT INDICATE THAT THE WATER IS


FOR POTABLE USE.

N.B: Excessive Turbidity if any may be removed before use.

Note :- UO=Unobjectionable. Fit=Fit for Potable use. Unfit=Unfit for Potable use.

O.W.No. DLN/ 560

Date: 29/01/2019



[Signature]
 Principal
 Shri Swaminarayan International
 Gunatit Vidyadham
 Chikhli, Dist. Navsari